

Wiring an IP20 Gateway to a DX85 Remote I/O device

Label	Gateway, DX85*
V+	+ 10 to 30V dc Input
Tx	RS485 / D1 / B / +
V-	dc common (GND)
Rx	RS485 / D0 / A / -
B+	

* Connecting dc power to the communication pins will cause permanent damage.

DX85...C Modbus RTU Remote I/O Device

DX80...C Gateway

