




Device Test Report

TMG IO-Link Device Tool V5.1 - TS: Revision: 5.1.1 Build: 8868
TEngBas V5.1.1: Revision: 5.1.1 Build: 8861
Test ID: 794568073



Vendor ID : 451 Vendor : Banner Engineering Corporation
Device ID : 663553 Device : S15S-TH-KQ
IO-Link Version : V1.1 Product ID : S15S-TH-KQ
Firmware Revision : 242376 Hardware Revision : 1.0
Serial Number : 000002

ISDU supported : True SIO mode supported : False
Process Data Input Bits : 112 Process Data Output Bits : 0
Min Cycle Time : 4000 μ s Bitrate : COM2

Implemented Access Locks :

parameter="False" datastorage="False" localParameterization="False" localUserInterface="False"

IODD : Banner_Engineering-S15S-TH-KQ-20250306-IODD1.1.xml

Checker : IODD-Checker V1.1.11 IODD Stamp : 2498086318

Test conditions: Test according IO-Link specification V1.1.3

Test result : All test were passed with positiv result in complete operation.

Test operated by :

Company : Banner Engineering

Name : Fathi Hassen

Signature :